

Request for Bid Rodney Baber Park Sewer Improvements Addendum # 1 to RFB No. 192442.71.0402 May 17, 2016



The following information encompasses Addendum # 1 for the above referenced RFB. Bidders shall fully consider and acknowledge this Addendum in the preparation and submittal of its formal Bid. Failure to do so may result in the rejection of the Bid.

- Section 1 Mandatory Pre-Bid Meeting Notes and Sign-In Sheet
- Section 2 Updated Selection Schedule

All other conditions and requirements remain unchanged

Mandatory Pre-Bid Meeting Notes and Sign-In Sheet

Q1: How large of a construction easement does the contractor have to work with? **SARP10:** 100' x 100' at the tie in manholes, 20' width along the boring alignment. Contractor will have site access as needed to complete the service line.

Q2: Is there an existing structure where the proposed line ties into the 84"? **SARP10:** Yes, the 24" line will tie into the existing structure. This will be clarified on the revised Construction Documents that will be issued in Addendum 2.

Q3: What kind of abandonment is being done on the 36" line? **SARP10:** See detail in Construction Drawings

Q4: What is being done about the sinkholes on the 36"? **SARP10:** Addressing the sinkholes are outside the scope of this project

Q5: Will the new manholes have a special coating on the inside? **SARP10:** No.

PLEASE NOTE:

The number assigned to this RFB has been updated from 179821.71.0402 to 192442.71.0402





SIGN-IN SHEET					
Project:	SARP10 Rodney Baber Park Sewer Improvements	Meeting Date:	May 12, 2016		
Meeting:	Pre-Bid Meeting	Time:	9:30 A.M.		
Facilitator:	Justin Avent	Place/Room:	Benjamin L. Hooks Central Library		

Name	Company	Phone	E-Mail
Justin Avent	SARPID	901-899- 6554	justin-aventossphet-com
GREG JOHES	LDA	865-573- 7672	GJOHES@LDAENgineering.com
William Hammond	HEMPHILL CONST	601 932-2060	L CAMPBELL @ HEMPHill CONSTRUCTION, COM
JOSH LANTRIP	Trench Safety & Supplu		
Steven Simon	Trench Safety + Supplu)	Srsimon@trenchsafety.com
Terry Richards			terrellrichards250@amail.co
Wil of Culards	WFT CONTRA Cop		11 Wile Richards at MSN. Con
Albert Johnson			
JASON BROOKS		865.368.3187	jbrooks@ Idaengineering.com
Terrence L. Fendleton		901-581-0053	Kencavil@aol.com
Ron HALL	SCOTT CONTRACTORS	901-3861981	RONCECOTT CONTRACTORS. COM
Rita Jorgensen	Scott Contractors	386 - 198) 901 - 808	rita@scottcontractors.com
Doug Earthonen	Gestechnology	201-355-5298	dearthunante gestechnolog. ca
Rick Pershull	(1 (1	1) []	rperchallegentechnology con
PINKY DIRE	PROS, FE CONSTRUCT	on 901-359-0273	hpdike @ prosite lle.com
Paul Gavin			paul, gavin Cads-pipe, com
Brock Steward			bsternt Ovive service 45 company. con
		<u>´</u> 1	





Name	Company	Phone	E-Mail
Hichge Roles	XYEM	90-481-1543	JITIN TEC MAGNOLISVNOERGADUD.
JAMES HiNTE	MAGNO DO UND.	901.238.7985	JITIN TEC MAGNO L'AVNOERGAD W.
KEVIN HURLEY	MAENOLIA	901-601-6019	Khusley Waynoliamderground. US
Patricia Condorn			Office D sual bussiness serve ne
Leon Yar brough	APS Facility Maint.	901-797-8988	lyarbrough Apsmemphis com
Lorenzo Myrick	ARS	901 97	Imyrick e apsmemphisicom
	River Services Compa	, 985-579-638	Muilson Driverservice son
			KArlico @ cerrescurers.com
Scott MiAmis		/	
Michael Jankins	M) confronting	Jol-49-2484	Jonking 120 compating
	U		
L		I	



Request for Bid Rodney Baber Park Sewer Improvements Addendum # 1 to RFB No. 192442.71.0402 May 17, 2016



Updated Selection Schedule (RFB Section 00170.16)

Event	Completed By
Advertising date	May 5, 2016
Pre-Bid meeting	May 12, 2016
Registration Information submitted per Advertisement	May 16, 2016
Issue Addendum 1 for answers to questions	May 17, 2016
Issue Addendum 2 (revised CD's) **	May 19, 2016
Last day for questions	May 25, 2016
Issue Addendum 3 Answering Questions (if necessary)	May 27, 2016
Public Bid Opening	June 2, 2016 at 3:00 P.M.
Tentative Pre construction Conference with Contractor	June 14, 2016
Tentative Issue Notice to Proceed	June 16, 2016

**Included in Addendum 2, will be revised construction documents