



Request for Bid
Front Street & Mud Island Interceptor Rehab Addendum # 3 to
RFB No. 179821.71.0404
January 26, 2016



The following information encompasses Addendum # 3 for the above referenced RFB. Bidders shall fully consider and acknowledge this Addendum in the preparation and submittal of its formal Bid. Failure to do so may result in the rejection of the Bid.

Section 1 – Revision to Addendum #2 Answer to Question 6

All other conditions and requirements remain unchanged

Revision to Addendum #2 Answer to Question 6

Q6: Will it be permitted to install dog house manholes on both the 24” & 60” SS lines? If so, can the engineer provide specifications for these dog house manholes?

SARP10: ~~SARP10 does not intend for any new manholes to be installed as part of this project.~~

SARP10 will allow the installation of a permanent manhole structure to aid with the bypass and be left when the job is complete. The design of this structure shall be approved by SARP10 prior to installation, and the cost should be included with the bypass pumping.